



Product Service

# CERTIFICATE

No. Z10 075157 0031 Rev. 01

**Holder of Certificate:** Pizzato Elettrica s.r.l.  
Via Torino 1  
36063 Marostica (VI)  
ITALY

**Certification Mark:**



**Product:** Safety components  
Programmable Safety Controller

**Model(s):** Gemnis CS M

**Parameters:** Ambient temperature: 0 °C...+55 °C (-25 °C...+65 °C, T1 version)  
Response time: < 30 ms  
(< 40 ms for relay output versions)  
Operating voltage: 24 Vdc ±15%

The report PM88729C is a mandatory part of this certificate.  
The product complies with the following listed safety requirements only, if the specifications documented in the currently valid revision of this report are met.

**Tested according to:** EN ISO 13849-1:2015 (Cat.4, PL e)  
EN 61508-1:2010 (SIL 3)  
EN 61508-2:2010 (SIL 3)  
EN 61508-3:2010 (SIL 3)  
EN IEC 62061:2021 (maximum SIL 3)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** PM88564T

**Valid until:** 2029-07-15

**Date,** 2024-07-16

( Christian Dirmeier )