



Product Service

# EC-Type Examination Certificate

No. M6A 17 05 75157 017

**Holder of Certificate:** Pizzato Elettrica s.r.l.Via Torino 1  
36063 Marostica (VI)  
ITALY**Product:** Safety components  
Safety control unit**Model(s):** CS FS-2x/3x/5x  
For nomenclature see attachment

<b>Parameters:</b>	Supply Voltage:	24 V DC $\pm 15\%$ 120 V AC $\pm 15\%$
	Power consumption:	5 VA max AC 2 W max DC
	Output switching current (max):	4 A
	Output switching power (max):	1380 VA
	Working temperature:	-25°C...+55°C
	Storage temperature:	-25°C...+70°C
	IP code:	20 Terminals, 40 Housing

This EC Type Examination Certificate is issued according to Article 12(3) b or 12(4) a of Council Directive 2006/42/EC relating to machinery. It confirms that the listed Annex-IV equipment complies with the principal protection requirements of the directive. It refers only to the sample submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

**Test report no.:** PM84261T**Valid until:** 2022-05-16**Date,** 2017-05-17

( Jürgen Blum )



TÜV SÜD Product Service GmbH is Notified Body according to Council Directive 2006/42/EC relating to machinery, notified by publication in the Official Journal of the EC with identification No. 0123.

Page 1 of 2



**Attachment to EC-Type Examination Certificate  
No. M6A 17 05 75157 017**

**Nomenclature of CS FS-2x/3x/5x**

**Delay ON timer**

**CS-FS 2wXY-aazzz**

zzz : fixed or f.s. time (operating time)

**Delay OFF timer**

**CS-FS 3wXY-aazzz**

zzz : fixed or f.s. time (releasing time)

**Delay OFF timer at the opening of the input channels**

**CS-FS 5wXY-aazzz**

zzz : releasing time tA or f.s.

**w- delay time**

w = 0: fixed time or custom selectable delay version (together with TSzzz option)

w = 1: max 3 sec. adjustable in 10 steps by 0.3 sec

w = 2: max 10 sec. adjustable in 10 steps by 1 sec

w = 3: max 30 sec. adjustable in 10 steps by 3 sec

w = 4: max 300 sec. adjustable in 10 steps by 30 sec

**X- connection type**

X = V: screw terminals

X = M: connector with screw terminals

X = X: connector with spring terminals

**Y- Voltage supply**

Y = U24: 24 Vdc +/- 15%

Y = 120: 120 Vac +/-15% (B1-B2) and 24 Vdc +/-15% (A1-A2)

aa = TF: fixed time (on fixed time models only)

aa = TS: selectable full scale time (on special f.s. versions only)

## Zertifizierungsvertrag

Grundlage für die Zertifikatserteilung ist die Prüf- und Zertifizierungsordnung von TÜV SÜD Product Service.

Mit Erhalt des Zertifikates erkennt der Zertifikatsinhaber die jeweils gültige Fassung der Prüf- und Zertifizierungsordnung an ([www.tuev-sued.de/ps\\_regulations](http://www.tuev-sued.de/ps_regulations)) und wird somit Partner im Zertifizierungssystem von TÜV SÜD Product Service.

### Prinzipielle Voraussetzung für die Gültigkeit des Zertifikates:

– Gültigkeit der zitierten normativen Prüfgrundlage(n) ist gegeben

und zusätzlich bei Zertifikaten mit Berechtigung zur Verwendung eines Prüfzeichens bzw. bei Zertifikaten für QM-Systeme:

– Voraussetzungen für vorschriftsmäßige Fertigung werden eingehalten.

– Die Fertigungs- bzw. Betriebsstätten werden regelmäßig überwacht.

## Certification contract

Certification is based on the TÜV SÜD Product Service Testing and Certification Regulations.

On receipt of the certificate the certificate holder agrees to the current version of the Testing and Certification Regulations ([www.tuev-sued.de/ps\\_regulations](http://www.tuev-sued.de/ps_regulations)) and thus becomes partner in the TÜV SÜD Product Service Certification System.

### Requirements for the validity of the certificate in principle:

– Validity of the quoted test standard(s)

In addition for certificates with the right to use a certification mark and for QM certificates:

– Conditions for an adequate manufacturing are maintained

– Regular surveillance of the facility is performed

Akkreditierungen / Benennungen (Status 25.02.2010) /  
Accreditations / notifications (as of 2010-02-25)

## Deutschland / Germany

Geräte- und Produktsicherheitsgesetz (GPSG) /  
Equipment and Product Safety Act (GPSG)

## Europa / Europe

- Niederspannungsrichtlinie 2006/95/EG
- Spielzeugrichtlinie 2009/48/EG
- Richtlinie für aktive medizinische Implantate 90/385/EWG
- Richtlinie für Medizinprodukte 93/42/EWG
- Richtlinie für In-vitro-Diagnostika 98/79/EG
- Richtlinie für Gasverbrauchseinrichtungen 90/396/EWG
- Richtlinie für persönliche Schutzausrüstungen 89/686/EWG
- EMV-Richtlinie 2004/108/EG
- Richtlinie für Sportboote 94/25/EG + 2003/44/EG
- Richtlinie für Maschinen 2006/42/EG
- Richtlinie für Ex-Schutz Geräte 94/9/EG
  
- Low Voltage Directive 2006/95/EC
- Toys Directive 2009/48/EC
- Directive for Active Implantable Medical Devices 90/385/EEC
- Directive for Medical Devices 93/42/EEC
- Directive on In Vitro Diagnostic Medical Devices 98/79/EC
- Directive for Gas Appliances 90/396/EEC
- Directive for Personal Protective Equipment 89/686/EEC
- EMC Directive 2004/108/EC
- Directive for Recreational Craft 94/25/EC + 2003/44/EC
- Directive for Machinery 2006/42/EC
- Directive for Ex Safe Equipment 94/9/EC
  
- ENEC Agreement for luminaires and IT equipment

## USA

- Nationally Recognized Testing Laboratory (NRTL) to 29 CFR 1910.7 by OSHA
- Accredited for FDA 510(k) Third Party Review
- Conformity Assessment Body to the MRA for Medical Devices; FDA QSR Reg Inspections, FDA 510(k) Third Party Review

## Asien-Pazifik Region / Asia Pacific

- Recognized Certification Body to Electrical Products (Safety) Regulation; Hong Kong
- Konformitätsbewertungsstelle / Conformity Assessment Body to the MRA for Medical Devices; Australien / Australia
- Konformitätsbewertungsstelle / Conformity Assessment Body to the MRA for Medical Devices; Neuseeland / New Zealand

## Weltweit / Worldwide

- NCB im CB-Scheme des IECEE / NCB in the CB Scheme of IECEE
- ExCB im IECEX-Scheme des IECEE / ExCB in the IECEX Scheme of IECEE
- TÜV SÜD Product Service Mark für Produkte / TÜV SÜD Product Service Mark for products DAP-ZE-1213.00
- Zertifizierung von QMS / Certification of QMS TGA-ZM-08-93-00
- Zertifizierung von QMS gemäß / Certification of QMS according to (DIN) EN ISO 13485 / ISO 13485