



Product Service

# CERTIFICATE

No. Z10 075157 0033 Rev. 00

**Holder of Certificate:** Pizzato Elettrica s.r.l.  
Via Torino 1  
36063 Marostica (VI)  
ITALY

**Certification Mark:**



**Product:** Safety components  
BP series "P-Connect"

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** PM101195T

**Valid until:** 2028-08-09

**Date,** 2023-08-11

( Peter Weiß )



Product Service

# CERTIFICATE

No. Z10 075157 0033 Rev. 00

**Parameters:**  
Operating Voltage: 24 Vdc  $\pm$ 15%  
Working temperature: -15°C ... +50°C  
Pollution degree: 2  
Overvoltage category: III

**Tested according to:**  
IEC 61508-1:2010 (SIL 3)  
IEC 61508-2:2010 (SIL 3)  
IEC 61508-3:2010 (SIL 3)  
EN ISO 13849-1:2015 (PL e, Cat. 4)  
EN IEC 62061:2021 (maximum SIL 3)  
EN 61326-3-1:2017

**Model(s):** **BP Gateway**

**BP a b c d e fff**

with:

**a: Housing Shape and Material**

A: Aluminum box, IP65 grade, size 141x166x64 mm, painted Grey

**b: Type of board**

1: Internal board

**c: Communication protocol**

P: PROFIsafe (PROFINET)

**d: Signaling**

L: 3 embedded LEDs

**e: Power supply connectors**

2: 2 x M12, 5 pin A coded

**fff: I/O external connections configuration**

001: Configuration 1

002: Configuration 2

003: Configuration 3

(other configurations on request)

Three alphanumeric digits (non-safety related)