中国国家强制性产品认证证书

证书编号：2024010305654836

认证委托人名称及地址

PIZZATO ELETTRICA S.R.L.
Via Torino.1 36063 Marostica(VI), Italy

生产者名称及地址

PIZZATO ELETTRICA S.R.L.
Via Torino.1 36063 Marostica(VI), Italy

生产企业名称及地址

PIZZATO ELETTRICA S.R.L.
Via Torino 2/A, 36063 Marostica (VI), Italy

产品名称和系列、型号、规格

微动开关

FS;Ui: 400V, 500V(contact block 接触块 66, 18);Uimp：4kV, 6kV(contact block 接触块 66, 18);AC-15: Ue/Ie: AC400V/3A;Ith: 10A;外壳防护等级：IP67;型号解释见附页

产品标准和技术要求

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》（CNCA-C03-02:2024）的要求，特发此证。

发证日期：2024 年 07 月 31 日 **有效期至：**2029 年 07 月 09 日

本证书为变更证书，证书首次颁发日期：2024 年 07 月 10 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

签发：

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

中国国家强制性产品认证证书

证书编号：2024010305654836

型号的解释(Explanation of / type):

FS	18	96	D	024	Further alphanumeric code extension indicating design or constructional better variants on customer's request 代码会根据客户对设计和结构的变体要求产生更多扩展
I	II	III	IV	V	

I: series 系列名

Series 系列名	
FS	Series with solenoid 带电磁阀

本页为证书附页，应与证书主页同时使用。

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

中国国家强制性产品认证证书

证书编号：2024010305654836

II: Contact block 接触块

Contact block 接触块		
18	Zb	Changeover, double gap, contact element with electrically separated moving contacts, dependent action. Contact unit with direct opening operation. Contact element 1NC+1NO operated by electromagnet. 转换，双间隙，带电分离动触头的接触元件，依赖动作。直接打开操作的接触单元。由电磁铁操作的接触元件 1NC + 1NO
20	Y+Y+X	2 normally closed and 1 normally open, double gap, contact elements with electrically separated moving contacts, dependent action. Contact unit with direct opening operation. Contact element 2NC+1NO operated by electromagnet. 2 个常闭和 1 个常开双间隙接触元件，带有电气分离的动触头，依赖动作。直接打开操作的接触单元。由电磁铁操作的接触元件 2NC + 1NO。
21	Y+Y+Y	3 normally closed, double gap, contact element with electrically separated moving contacts, dependent action. Contact unit with direct opening operation. Contact element 3NC operated by electromagnet. 3 个常闭，双间隙，带电分离动触头的接触元件，依赖动作。直接打开操作的接触单元。由电磁铁操作的接触元件 3NC。
22	Y+X+X	1 normally closed and 2 normally open, double gap, contact elements with electrically separated moving contacts, dependent action. Contact unit with direct opening operation. Contact element 1NC+2NO operated by electromagnet. 1 个常闭和 2 个常开双间隙接触元件，带有电气分离的动触头，依赖动作。直接打开操作的接触单元。由电磁铁操作的接触元件 1NC + 2NO。
28	Y+Y+X	2 normally closed and 1 normally open, double gap, contact elements with electrically separated moving contacts. Contact unit with direct opening operation. Contact element 1NC+1NO operated by electromagnet and 1NC operated by key. 2 个常闭和 1 个常开双间隙接触元件，带有电气分离的动触头。直接打开操作的接触单元。触点元件 1NC + 1NO 由电磁铁操作，1NC 由键操作。
29	Y+Y+Y	3 normally closed, double gap, contact elements with electrically separated moving contacts. Contact unit with direct opening operation. Contact element 2NC operated by electromagnet and 1NC operated by key. 3 个常闭，双间隙，带电分离动触头的接触元件。直接打开操作的接触单元。接触元件 2NC 由电磁铁操作，1NC 由钥匙操作。
30	Y+Y+Y	3 normally closed, double gap, contact elements with electrically separated moving contacts. Contact unit with direct opening operation. Contact element 1NC operated by electromagnet and 2NC operated by key. 3 个常闭，双间隙，带电分离动触头的接触元件。直接打开操作的接触单元。接触元件 1NC 由电磁铁操作，2NC 由钥匙操作。
66	Y	1 normally closed, double gap, dependent action. Contact unit with direct opening operation. Contact element 1NC operated by electromagnet. 1 常闭，双间隙，依赖动作。直接打开操作的接触单元。由电磁铁操作的接触元件 1NC。

本页为证书附页，应与证书主页同时使用。

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE
中国质量认证中心有限公司
http://www.cqc.com.cn 北京市丰台区南四环西路188号九区5号楼 100070 电话：+86 10 83886666

中国国家强制性产品认证证书

证书编号：2024010305654836

III: Actuation head 启动器头部

Actuation head 启动器头部	
96	Operating key 操作键
98	Operating key with interlock 带互锁的操作键

IV: Working principle 工作原理

Working principle 工作原理	
D	Key locked with de-energized solenoid 断电电磁阀锁定的键
E	Key locked with energized solenoid 通电电磁阀锁定的键

V: Solenoid supply voltage 电磁阀供电电压

Solenoid supply voltage 电磁阀供电电压	
024	24 Vac/dc
120	120 Vac/dc
230	230 Vac

本页为证书附页，应与证书主页同时使用。

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE
中国质量认证中心有限公司
http://www.cqc.com.cn 北京市丰台区南四环西路188号九区5号楼 100070 电话：+86 10 83886666

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010305654836

NAME AND ADDRESS OF THE APPLICANT

PIZZATO ELETTRICA S.R.L.
Via Torino.1 36063 Marostica(VI), Italy

NAME AND ADDRESS OF THE MANUFACTURER

PIZZATO ELETTRICA S.R.L.
Via Torino.1 36063 Marostica(VI), Italy

NAME AND LOCATION OF THE FACTORY

PIZZATO ELETTRICA S.R.L.
Via Torino 2/A, 36063 Marostica (VI), Italy

PRODUCT NAME,MODEL AND SPECIFICATION

Micro Switch
FS;Ui: 400V, 500V(contact block 66, 18);Uimp：4kV, 6kV(contact block 66, 18);AC-15: Ue/Ie: AC400V/3A;Ith: 10A;IP67;See the appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.31,2024 **Valid until:** Jul.09,2029

Date of original issued: Jul.10,2024

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

http://www.cqc.com.cn Building 5, Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86 10 83886666

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010305654836

型号的解释(Explanation of / type):

FS	18	96	D	024	Further alphanumeric code extension indicating design or constructional better variants on customer's request 代码会根据客户对设计和结构的变体要求产生更多扩展
I	II	III	IV	V	

I: series 系列名

Series 系列名	
FS	Series with solenoid 带电磁阀

This page is attached to the certificate and should be used at the same time as the certificate page.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010305654836

II: Contact block 接触块

Contact block 接触块		
18	Zb	Changeover, double gap, contact element with electrically separated moving contacts, dependent action. Contact unit with direct opening operation. Contact element 1NC+1NO operated by electromagnet. 转换，双间隙，带电分离动触头的接触元件，依赖动作。直接打开操作的接触单元。由电磁铁操作的接触元件 1NC + 1NO
20	Y+Y+X	2 normally closed and 1 normally open, double gap, contact elements with electrically separated moving contacts, dependent action. Contact unit with direct opening operation. Contact element 2NC+1NO operated by electromagnet. 2 个常闭和 1 个常开双间隙接触元件，带有电气分离的动触头，依赖动作。直接打开操作的接触单元。由电磁铁操作的接触元件 2NC + 1NO。
21	Y+Y+Y	3 normally closed, double gap, contact element with electrically separated moving contacts, dependent action. Contact unit with direct opening operation. Contact element 3NC operated by electromagnet. 3 个常闭，双间隙，带电分离动触头的接触元件，依赖动作。直接打开操作的接触单元。由电磁铁操作的接触元件 3NC。
22	Y+X+X	1 normally closed and 2 normally open, double gap, contact elements with electrically separated moving contacts, dependent action. Contact unit with direct opening operation. Contact element 1NC+2NO operated by electromagnet. 1 个常闭和 2 个常开双间隙接触元件，带有电气分离的动触头，依赖动作。直接打开操作的接触单元。由电磁铁操作的接触元件 1NC + 2NO。
28	Y+Y+X	2 normally closed and 1 normally open, double gap, contact elements with electrically separated moving contacts. Contact unit with direct opening operation. Contact element 1NC+1NO operated by electromagnet and 1NC operated by key. 2 个常闭和 1 个常开双间隙接触元件，带有电气分离的动触头。直接打开操作的接触单元。触点元件 1NC + 1NO 由电磁铁操作，1NC 由键操作。
29	Y+Y+Y	3 normally closed, double gap, contact elements with electrically separated moving contacts. Contact unit with direct opening operation. Contact element 2NC operated by electromagnet and 1NC operated by key. 3 个常闭，双间隙，带电分离动触头的接触元件。直接打开操作的接触单元。接触元件 2NC 由电磁铁操作，1NC 由钥匙操作。
30	Y+Y+Y	3 normally closed, double gap, contact elements with electrically separated moving contacts. Contact unit with direct opening operation. Contact element 1NC operated by electromagnet and 2NC operated by key. 3 个常闭，双间隙，带电分离动触头的接触元件。直接打开操作的接触单元。接触元件 1NC 由电磁铁操作，2NC 由钥匙操作。
66	Y	1 normally closed, double gap, dependent action. Contact unit with direct opening operation. Contact element 1NC operated by electromagnet. 1 常闭，双间隙，依赖动作。直接打开操作的接触单元。由电磁铁操作的接触元件 1NC。

This page is attached to the certificate and should be used at the same time as the certificate page.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010305654836

III: Actuation head 启动器头部

Actuation head 启动器头部	
96	Operating key 操作键
98	Operating key with interlock 带互锁的操作键

IV: Working principle 工作原理

Working principle 工作原理	
D	Key locked with de-energized solenoid 断电电磁阀锁定的键
E	Key locked with energized solenoid 通电电磁阀锁定的键

V: Solenoid supply voltage 电磁阀供电电压

Solenoid supply voltage 电磁阀供电电压	
024	24 Vac/dc
120	120 Vac/dc
230	230 Vac

This page is attached to the certificate and should be used at the same time as the certificate page.